


Melbourne City
Council

Passive Design Report

Prepared for:
Melbourne City Council

Prepared by:
Advanced Environmental
Concepts Pty Ltd
CAN 075 117 243
Level 1, 41 McLaren Street
North Sydney NSW 2060



design advice

passive systems

design analysis

low energy services

March 03

AESY820000\0\2\SFT30301\Draft.0

EXECUTIVE SUMMARY

This report has been prepared by Advanced Environmental Concepts to examine several options affecting the thermal performance of the proposed Melbourne City Council building.

The report is divided into three sections. Each section focuses on one aspect which will thermally affect the building and explores several options. Using computer simulations we find the optimum solution for each aspect.

The first aspect considered is building ventilation. Air conditioning and natural ventilation options were modelled during different weather conditions to predict the effectiveness of natural ventilation during summer, mid-season and winter, especially when cooling the building at night using natural ventilation.

The second aspect considered is optimising night purging. Different free/open window areas as a percentage of floor areas were modelled to show their effectiveness in affecting space cooling throughout the year.

The third and last aspect is external wall analysis. Three different materials were modelled in the building's external wall during summer, mid-season and winter and their thermal performance analysed ie the effect they have on the temperature inside the building.

The aim of the report is to recommend options which provide and maintain good levels of thermal comfort year round.

TABLE OF CONTENTS

EXECUTIVE SUMMARY	I
TABLE OF CONTENTS	II
LIST OF FIGURES	III
1 INTRODUCTION	1
2 APPROACH	1
3 VENTILATION STRATEGY	3
3.1.1 Summer conditions	3
3.1.2 Mid-season conditions	3
3.1.3 Winter conditions	4
4 OPTIMISING NIGHT PURGING	7
5 THERMAL MASS OF EXTERNAL WALLS	8
6 CONCLUSIONS AND RECOMMENDATIONS	10
APPENDIX A – VENTILATION STRATEGY RESULTS	
APPENDIX B – EXTERNAL WALL THERMAL MASS RESULTS	

Date	10 March 2003	
Revision and Status		
Author	Su-fern Tan	
Project Team Leader	Mark Cummins	

LIST OF FIGURES

Figure 1 Cooling loads on a typical summer's day for ventilation options.....	3
Figure 2 Cooling loads on a typical mid-season day for ventilation options	4
Figure 3 Cooling loads on a typical winter's day for ventilation options.....	4
Figure 4 Load breakdown for naturally ventilated option	5
Figure 5 Load breakdown for air conditioned + night purging option	5
Figure 6 Load breakdown for air conditioned + no night purging option.....	5
Figure 7 Load comparison for ventilation options.....	6
Figure 8 Free window area effects on space cooling.....	7
Figure 9 Cooling loads for wall element options	8
Figure 10 Effect on cooling loads for external wall options.....	9

1 INTRODUCTION

This study examines 3 aspects of the proposed Melbourne City Council Building which will affect its thermal performance.

1. Natural ventilation strategy options modelled:
 - naturally ventilated with no air conditioning
 - air conditioned with night purging
 - air conditioned building with no night purging

2. Night purge optimisation options modelled(expressed as a percentage of total floor area):
 - 0%
 - 1%
 - 2%
 - 3%
 - 4%
 - 5%

3. External wall thermal mass options modelled to test the effectiveness of using thermal mass at the external walls for this building are:
 - concrete
 - autoclaved aerated concrete
 - plasterboard

Using Thermal Analysis Software, results were produced for each option showing their effects on temperatures and loads, radiant temperatures, air flows, resultant temperatures and air temperatures.

2 APPROACH

The graphical results for each option are attached in the Appendices. They show temperatures and loads, radiant temperatures, air flows (where relevant), frequency of resultant temperatures, and frequency of air temperatures.

2.1 Temperatures and Loads

The temperatures and loads data gives hourly air temperature and sensible load data in a specific zone on a given day. We have chosen days which represent in Melbourne:

- a typical hot summer's day
- a typical mid-season (spring/autumn) day
- a typical cold winter's day

Air temperatures are calculated by balancing heat gains and losses influenced by infiltration, ventilation, air movement, occupants, equipment, lighting, solar gains and, plant and surface convection.

The sensible load graph represents the amount of energy required of the air conditioning plant to offset the air temperature and maintain the space within the required limits of 20-25°C.

2.2 Radiant Temperatures

The radiant temperature is an hourly estimate of an occupant's perception of the radiant temperature of the zone on a specific day. It is what an occupant feels from

the temperatures and emissivities of her/his surrounding surfaces. It is calculated as an average of the zone's surface temperatures modified by the effects of radiant gains from plant, incidental and solar gain. Radiant temperatures were also compared under the same three typical weather conditions.

2.3 Resultant Temperatures

The resultant temperature is a combination of the air temperature and radiant temperatures in a space. Resultant temperature explains why standing next to a sunny window inside feels hotter than standing in an enclosed office in the same building. The air temperature of both areas is the same, but due to a higher radiant temperature, the resultant temperature is higher at the façade.

Each option will show its hourly resultant temperature on a given day that represents its typical weather condition.

2.4 Air Flows

The air flow diagrams show how much air is flowing in and out of one area into another. In our results we show firstly, the air flow from outside into a typical perimeter zone, zone 8. This is how we can see how much fresh air is entering the building. Then we show the air flows between the perimeter zone and the centre zone, zone 10, to see how much fresh air is passing into the office spaces.

2.5 Frequency of Resultant Temperatures

The frequency resultant temperature graphs show the distribution of resultant temperatures measured in hours throughout the year in that particular zone. In our results we look at both zone 8, the perimeter zone, and zone 10, the centre zone.

2.6 Frequency of Air Temperatures

The frequency air temperature graphs show the distribution of air temperatures measured in hours throughout the year in that particular zone. Similarly, we look at both the frequency of air temperatures in both perimeter and centre zones.

2.7 Load Breakdowns

The load breakdown graphs show the different loads which are placed upon the building for the year. The loads include heating, cooling, humidify, dehumidify, internal, and solar loads.

3 VENTILATION STRATEGY

Ventilation is required to provide occupants with metabolic oxygen requirements, remove or dilute air pollutants, and provide cooling. For most buildings, 40% of energy consumption is used for air conditioning. Depending on climate and location, it is possible to reduce a building's energy consumption by utilising natural ventilation.

Natural ventilation can affect both energy consumption and ventilation effectiveness, hence indoor air quality and comfort.

The results in this section show the cooling and heating loads experienced by the proposed Melbourne City Council building in summer, mid-season and winter when we use natural ventilation and/or air conditioning. We used computer modelling and test reference Melbourne weather files were to produce results.

3.1 Results

3.1.1 Summer conditions

During a typically hot summer's day, when the building is fully naturally ventilated the resultant temperature of the office during working hours are at approximately 25°C in the morning and increases hourly until its peak of 33°C at 6pm. We can also see that the maximum temperature experienced in summer is 37°C (see Appendix A, section 1.1). This indicates that during summer, a fully naturally ventilated building is unsuitable and air conditioning is necessary.

During night time, when the cooling load has been reduced drastically by the absence of the sun, occupants, equipment and lighting, we can look to natural ventilation to help us cool the building. This will reduce the load on the air conditioning plant, increase energy and cost savings, and reduce greenhouse gas emissions. The use of night purging would reduce daily cooling load requirements by approximately 14% on a summer's day.

The table below summarises the daily cooling load requirements for the three different ventilation options.

It is highly recommended that during summer, air conditioning be used during working hours to maintain comfort levels; and night purging be utilised to reduce the cooling plant load and reduce energy consumption.

per day loads	Fully naturally ventilated	Air cond with night purging	Air cond with no night purging
Load/area (kWh/m ²)	0	0.35 (cooling)	0.40 (cooling)
Load for 1 level (kWh)	0	224 (cooling)	259 (cooling)
Load for total building (kWh)	0	2019 (cooling)	2332 (cooling)

Figure 1 Cooling loads on a typical summer's day for ventilation options

3.1.2 Mid-season conditions

During mid-season autumn and spring, results show that if the building was fully naturally ventilated, the resultant temperatures would remain between 21 – 23.5°C in

the office spaces on a typical day. This satisfies the design temperature limits of 20 - 25°C for comfort.

However, when we look at naturally ventilating the building during working hours, we have to consider factors such as air and noise pollution. Although energy reductions are a priority, indoor air quality must also be considered.

For the air conditioned buildings, the use of night purging would decrease cooling loads by 21%.

During mid-season, during working hours, the building will maintain thermal comfort levels without air conditioning however air and noise pollution must be considered whilst using natural ventilation.

per day loads	Fully naturally ventilated	Air cond with night purging	Air cond with no night purging
Load/area (kWh/m ²)	0	0.27 (cooling)	0.34 (cooling)
Load for 1 level (kWh)	0	176 (cooling)	223 (cooling)
Load for total building (kWh)	0	1583.4 (cooling)	2005.4 (cooling)

Figure 2 Cooling loads on a typical mid-season day for ventilation options

3.1.3 Winter conditions

In the naturally ventilated building, we find that the temperature consistently stays around 20 - 21°C in the office areas on a typical winter's day. Although the building does not have any cooling loads, the lower levels on the north side become too cold in the early morning before 9am, and minimal heating in the coldest perimeter zones will be required. (See Appendix A, section 2.4)

In the air conditioned buildings during winter, no heating will be necessary to maintain thermal comfort. The building will still need cooling to cope with occupant, equipment, lighting, solar, etc gains. The use of night purging would decrease the building's energy consumption (cooling load) by 36%.

Similar to mid-season conditions, there will be no need for air conditioning to maintain thermal comfort within the design requirements of 20 - 25°C. However consideration must be given to the affects of utilising natural ventilation on noise pollution and indoor air quality.

per day loads	Fully naturally ventilated	Air cond with night purging	Air cond with no night purging
Load/area (kWh/m ²)	0.004 (heating)	0.11 (cooling)	0.18 (cooling)
Load for 1 level (kWh)	2.41 (heating)	76 (cooling)	118 (cooling)
Load for total building (kWh)	22 (heating)	682 (cooling)	1058 (cooling)

Figure 3 Cooling loads on a typical winter's day for ventilation options

3.2 Load breakdowns

The following charts show the breakdown of the different types of loads as a proportion of total annual loads on the three types of ventilated MCC buildings modelled.

We can see that using night purging will reduce the cooling load on the building from about one third of total loads down to one quarter of total loads.




Figure 4 Load breakdown for naturally ventilated option




Figure 5 Load breakdown for air conditioned + night purging option




Figure 6 Load breakdown for air conditioned + no night purging option

If we compare all the options and their load breakdowns in one graph, we can see that natural ventilation contributes to a significant reduction in cooling loads.




Figure 7 Load comparison for ventilation options

4 OPTIMISING NIGHT PURGING

At night, it is normal that the air conditioning will turn off and the building will be cooled using natural ventilation. We call this process night purging. Night purging will depend on the amount of much free window area available.

Free window area is the area of a window which allows air to flow through. This free area is dependent on the openable proportion of the window. We measure free areas as a percentage of floor area of the space we want to cool.

For the proposed Melbourne City Council building we modelled six options of free window areas, from 0% to 5%, and the effect they have on cooling the office space.

4.1 Results

The graph below shows how free window areas affect space cooling in the Melbourne City Council building. We can see that after having 1% of free window area, the effect on space cooling loads is minimal.




Figure 8 Free window area effects on space cooling

Thus for night purging to be carried out successfully, we only have to achieve a free window area which is a minimum of 1% of the office floor area.

5 THERMAL MASS OF EXTERNAL WALLS

Thermal mass plays a role in the energy efficiency of a building. Materials with high thermal mass like concrete, store and release energy needed for heating and cooling more so than materials with low thermal mass like plasterboard. A building with good thermal mass is protected from big temperature swings and therefore will provide a higher level of thermal comfort year round.

5.1 Results

External walls with a variation in one building material were modelled on the MCC building. The aim is to show if the inclusion of thermal mass to the external walls by looking at their effects on air temperatures, radiant temperatures, resultant temperatures, and cooling loads.

The three materials modelled in the external walls are:

- 90mm concrete
- 90mm autoclaved aerated concrete (for example, Hebel)
- 12mm plasterboard.

Below is a table summarising the loads on the building reflecting the effects the different external walls have on cooling loads. We can see that only in winter do the external wall types slightly affect thermal mass (see Appendix B section 3.1). Following this, on the next page is a graphical representation of this.

Cooling loads per level in kWh	concrete wall	autoclaved aerated concrete wall	plasterboard wall
summer	224	225	227
mid-season	176	176	178
winter	75	80	86

Figure 9 Cooling loads for wall element options




Figure 10 Effect on cooling loads for external wall options

The results show that none of these materials had any significant effect on the heating and cooling loads for the proposed Melbourne City Council building so the selection of building materials for the external walls should be dependent on other factors other than thermal mass.

Thermal mass is most effective where it can offer maximum exposure to all building occupants. Thus utilising thermal mass in ceilings is much more effective than utilising thermal mass in external walls.

6 CONCLUSIONS AND RECOMMENDATIONS

This report has collated the results from a number of computer simulations to find an optimum solution for building ventilation, night ventilation effectiveness and external wall thermal mass for the proposed Melbourne City Council building.

A number of options were modelled and their thermal effects analysed for all weather conditions throughout the year using test reference data from Melbourne.

With regard to building ventilation, we recommend that air conditioning be used during summer to maintain thermal comfort. During typical mid-season and winter days, air conditioning will not be necessary to maintain thermal comfort levels but noise and indoor air quality need to be considered. If air conditioning is to be used, we strongly recommend night purging to reduce energy consumption and cooling plant loads for all periods throughout the year.

Night purging effects will be effective if 1% of the floor area is window area provided as openable/free. Results have shown that any increase in the free window area only marginally increases the effectiveness of space cooling.

Results show that there is not any significant change in the thermal mass benefits of the building when we consider external wall materials. Very small thermal mass benefits may be felt only during winter. We conclude that the choice of building material selection for the external walls could be dependent on other factors other than thermal mass.

APPENDIX A – VENTILATION STRATEGY RESULTS


*zone 8 = mid level perimeter zone

* zone 10 = mid level office zone

1 SUMMER – DAY 15

1.1 Fully Naturally Ventilated Option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
21	mcc_nightp	mcc_nv_sch.bdf.01	104	15:09:31	03:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wfl




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
23	mcc_nightp	mcc_nv_sch.bdf.01	104	15:12:59	03:Mar:03		A-Tas 8.40




Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside


Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wfl



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
26	mcc_nightp	mcc_nv_sch.bdf.01	104	15:15:26	03:Mar:03		A-Tas 8.40




Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	6.697	7.272	13	0.063	0.063
2	6.957	7.120	14	0.063	0.063
3	6.794	6.823	15	0.063	0.063
4	6.336	7.279	16	0.063	0.063
5	5.249	8.833	17	0.063	0.063
6	2.901	12.576	18	0.063	14.738
7	0.063	19.389	19	0.063	0.082
8	0.063	24.506	20	0.063	0.106
9	0.063	18.211	21	0.063	15.526
10	0.063	0.084	22	3.232	4.487
11	0.063	0.063	23	0.063	0.063
12	0.063	0.063	24	0.063	0.063




Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
72	mcc_nightp	mcc_nv_sch.bdf.01	104	15:36:47	03:Mar:03		A-Tas 8.40



Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	25.183	24.533	13	17.836	17.625
2	25.210	24.942	14	17.514	17.288
3	25.347	25.202	15	16.784	16.620
4	24.509	23.519	16	16.205	16.090
5	23.215	19.778	17	16.261	16.130
6	18.523	9.379	18	22.911	9.710
7	18.771	0.877	19	8.316	8.264
8	23.098	0.000	20	6.365	6.307
9	20.721	3.941	21	17.403	3.129
10	17.224	17.029	22	16.950	15.710
11	17.409	17.243	23	11.224	11.122
12	17.549	17.374	24	12.289	12.182




Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



1.2 Air Conditioned with Night Purging Option

Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
42	mcc_nightp	mcc_nightp.bdf.01	98	15:32:01	03:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	


Zone	Cooling (kWh)
7 n lvl 4,5,6	94.16
8 s lvl 4,5,6	85.21
9 w lvl 4,5,6	26.66
10 office 4,5,6	673.07
11 e lvl 7,8,9	47.53
12 n lvl 7,8,9	111.40
Outside	

Day 15: Monday, Jan 15 (WEEKDAY)


Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
44	mcc_nightp	mcc_nightp.bdf.01	98	15:32:53	03:Mar:03		A-Tas 8.40



Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside




Day 15: Monday, Jan 15 (WEEKDAY)


Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
45	mcc_nightp	mcc_nightp.bdf.01	98	15:33:52	03:Mar:03		A-Tas 8.40




Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	4.622	4.984	13	0.063	0.063
2	4.922	5.024	14	0.063	0.063
3	4.871	4.886	15	0.063	0.063
4	4.531	5.131	16	0.063	0.063
5	3.816	6.071	17	0.063	0.063
6	2.359	8.284	18	0.063	0.063
7	0.063	0.063	19	0.063	0.063
8	0.063	0.063	20	0.063	0.063
9	0.063	0.063	21	0.063	0.063
10	0.063	0.063	22	0.063	0.063
11	0.063	0.063	23	0.063	0.063
12	0.063	0.063	24	0.063	0.063




Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
62	mcc_nightp	mcc_nightp.bdf.01	98	15:34:35	03:Mar:03		A-Tas 8.40



Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	22.532	22.092	13	0.000	0.000
2	23.399	23.195	14	8.910	9.046
3	23.645	23.518	15	0.227	0.224
4	22.856	22.190	16	8.784	8.839
5	21.550	19.358	17	0.215	0.213
6	17.824	12.223	18	9.528	9.595
7	11.404	11.314	19	11.786	11.944
8	0.352	0.353	20	7.659	7.695
9	0.620	0.624	21	5.356	5.382
10	2.301	2.275	22	5.508	5.479
11	2.255	2.286	23	8.546	8.499
12	8.416	8.565	24	10.585	10.499




Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



1.3 Air Conditioned With No Night Purging Option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
87	ncc_nightp	ncc_nopurg.bdf.01	100	15:42:33	03:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	119.22
8 s lvl 4,5,6	116.76
9 w lvl 4,5,6	34.75
10 office 4,5,6	777.54
11 e lvl 7,8,9	53.21
12 n lvl 7,8,9	136.51
Outside	


Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
89	ncc_nightp	ncc_nopurg.bdf.01	100	15:43:07	03:Mar:03		A-Tas 8.40




Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside




Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
90	mcc_nightp	mcc_nopurg.bdf.01	100	15:43:38	03:Mar:03		A-Tas 8.40




Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	0.063	0.063	13	0.063	0.063
2	0.063	0.063	14	0.063	0.063
3	0.063	0.063	15	0.063	0.063
4	0.063	0.063	16	0.063	0.063
5	0.063	0.063	17	0.063	0.063
6	0.063	0.063	18	0.063	0.063
7	0.063	0.063	19	0.063	0.063
8	0.063	0.063	20	0.063	0.063
9	0.063	0.063	21	0.063	0.063
10	0.063	0.063	22	0.063	0.063
11	0.063	0.063	23	0.063	0.063
12	0.063	0.063	24	0.063	0.063




Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
99	mcc_nightp	mcc_nopurg.bdf.01	100	15:44:10	03:Mar:03		A-Tas 8.40



Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	12.466	12.385	13	8.095	8.207
2	14.126	14.030	14	0.000	0.000
3	14.529	14.433	15	0.348	0.344
4	14.462	14.365	16	1.016	1.024
5	14.418	14.321	17	0.000	0.000
6	14.158	14.056	18	0.892	0.901
7	12.906	12.728	19	10.269	10.334
8	0.493	0.490	20	5.422	5.445
9	0.000	0.000	21	4.462	4.439
10	0.000	0.000	22	7.991	7.944
11	0.000	0.000	23	9.960	9.893
12	0.000	0.000	24	11.464	11.382




Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



2 MID-SEASON – DAY 80

2.1 Fully Naturally Ventilated Option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
4	mcc_nightp	mcc_nv_sch.bdf.01	104	15:59:04	03:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	


Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
9	mcc_nightp	mcc_nv_sch.bdf.01	104	16:00:07	03:Mar:03		A-Tas 8.40




Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside




Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
10	mcc_nightp	mcc_nv_sch.bdf.01	104	16:00:36	03:Mar:03		A-Tas 8.40




Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	3.156	3.031
2	3.186	3.168
3	3.061	3.067
4	3.114	3.095
5	3.176	3.039
6	3.310	2.999
7	3.676	2.951
8	4.542	2.890
9	9.385	5.247
10	11.493	4.603
11	12.693	3.564
12	13.946	2.762
13	15.328	1.296
14	20.751	0.063
15	23.062	0.063
16	22.277	0.063
17	21.876	0.063
18	21.095	0.063
19	11.659	0.063
20	7.172	1.351
21	5.386	2.741
22	4.144	3.239
23	3.344	3.176
24	2.804	2.809




Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
19	mcc_nightp	mcc_nv_sch.bdf.01	104	16:01:03	03:Mar:03		A-Tas 8.40



Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	24.462	24.451
2	24.188	24.083
3	24.063	23.935
4	23.735	23.632
5	23.622	23.628
6	23.460	23.626
7	23.343	23.891
8	23.610	25.026
9	32.270	35.937
10	32.398	38.613
11	32.092	40.367
12	31.380	41.560
13	30.083	42.909
14	27.325	46.328
15	25.516	46.657
16	26.205	46.607
17	26.483	46.502
18	27.076	46.366
19	24.243	34.856
20	25.588	30.841
21	26.031	28.346
22	25.608	26.317
23	25.224	25.252
24	25.048	24.916




Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



2.2 Air Conditioned with Night Purging Option

Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
35	mcc_nightp	mcc_nightp.bdf.01	99	16:04:33	03:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	29.98
8 s lvl 4,5,6	12.25
9 w lvl 4,5,6	6.19
10 office 4,5,6	527.80
11 e lvl 7,8,9	17.56
12 n lvl 7,8,9	83.09
Outside	

Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
37	mcc_nightp	mcc_nightp.bdf.01	99	16:05:01	03:Mar:03		A-Tas 8.40




Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside


Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
38	mcc_nightp	mcc_nightp.bdf.01	99	16:05:26	03:Mar:03		A-Tas 8.40




Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	2.860	2.755	13	0.063	0.063
2	2.878	2.863	14	0.063	0.063
3	2.783	2.787	15	0.063	0.063
4	2.791	2.776	16	0.063	0.063
5	2.827	2.715	17	0.063	0.063
6	2.910	2.661	18	0.063	0.063
7	0.063	0.063	19	9.102	0.249
8	0.063	0.063	20	6.167	1.664
9	0.063	0.063	21	4.697	2.609
10	0.063	0.063	22	3.763	3.016
11	0.063	0.063	23	3.147	3.002
12	0.063	0.063	24	2.724	2.728




Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
47	mcc_nightp	mcc_nightp.bdf.01	99	16:05:48	03:Mar:03		A-Tas 8.40



Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	24.016	23.989	13	0.000	0.000
2	23.728	23.623	14	0.000	0.000
3	23.649	23.524	15	0.000	0.000
4	23.317	23.212	16	0.000	0.000
5	23.215	23.199	17	0.000	0.000
6	23.047	23.158	18	0.000	0.000
7	13.404	13.313	19	25.795	33.853
8	13.468	13.278	20	25.543	29.585
9	9.486	9.421	21	25.596	27.401
10	0.519	0.510	22	25.104	25.671
11	0.000	0.000	23	24.811	24.821
12	0.000	0.000	24	24.746	24.618




Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



2.3 Air Conditioned With No Night Purging Option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
63	mcc_nightp	mcc_nopurg.bdf.01	100	16:10:18	03:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	50.53
8 s lvl 4,5,6	40.48
9 w lvl 4,5,6	14.97
10 office 4,5,6	668.48
11 e lvl 7,8,9	22.02
12 n lvl 7,8,9	106.09
Outside	

Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
68	mcc_nightp	mcc_nopurg.bdf.01	100	16:10:53	03:Mar:03		A-Tas 8.40





Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside

Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
69	mcc_nightp	mcc_nopurg.bdf.01	100	16:11:21	03:Mar:03		A-Tas 8.40





Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	0.063	0.063	13	0.063	0.063
2	0.063	0.063	14	0.063	0.063
3	0.063	0.063	15	0.063	0.063
4	0.063	0.063	16	0.063	0.063
5	0.063	0.063	17	0.063	0.063
6	0.063	0.063	18	0.063	0.063
7	0.063	0.063	19	0.063	0.063
8	0.063	0.063	20	0.063	0.063
9	0.063	0.063	21	0.063	0.063
10	0.063	0.063	22	0.063	0.063
11	0.063	0.063	23	0.063	0.063
12	0.063	0.063	24	0.063	0.063

Day 00: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
78	mcc_nightp	mcc_nopurg.bdf.01	100	16:11:47	03:Mar:03		A-Tas 8.40



Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	14.562	14.451	13	0.000	0.000
2	14.543	14.427	14	0.000	0.000
3	14.560	14.442	15	0.000	0.000
4	14.508	14.386	16	0.000	0.000
5	14.519	14.395	17	0.000	0.000
6	14.458	14.329	18	0.000	0.000
7	14.220	14.051	19	12.016	11.893
8	8.882	8.843	20	13.629	13.517
9	0.183	0.181	21	14.037	13.931
10	0.000	0.000	22	14.384	14.277
11	0.000	0.000	23	14.698	14.595
12	0.000	0.000	24	14.990	14.888


Day 00: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



3 WINTER - DAY 180

3.1 Fully Naturally Ventilated Option

Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
21	ncc_nightp	ncc_nv_sch.bdf.01	104	16:02:02	03:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.52
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	7.24
Outside	


Zone	Cooling (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Day 180: Friday, Jun 29 (WEEKDAY)


Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
23	ncc_nightp	ncc_nv_sch.bdf.01	104	16:02:38	03:Mar:03		A-Tas 8.40



Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside




Day 180: Friday, Jun 29 (WEEKDAY)


Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
24	mcc_nightp	mcc_nv_sch.bdf.01	104	16:03:06	03:Mar:03		A-Tas 8.40




Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	0.721	2.973	13	3.430	3.338
2	0.844	1.828	14	3.197	3.158
3	0.846	1.449	15	3.048	3.039
4	0.779	1.300	16	2.955	2.927
5	0.654	1.197	17	2.605	3.156
6	0.602	1.072	18	2.415	3.251
7	0.546	1.177	19	0.766	1.011
8	0.377	1.145	20	0.705	0.687
9	0.063	0.063	21	0.614	0.599
10	0.063	0.063	22	0.547	0.532
11	0.063	0.063	23	0.490	0.475
12	3.651	3.479	24	0.414	0.400




Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
33	mcc_nightp	mcc_nv_sch.bdf.01	104	16:03:27	03:Mar:03		A-Tas 8.40



Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	15.314	13.198	13	33.641	33.552
2	19.197	18.194	14	33.288	33.151
3	20.153	19.464	15	33.141	32.976
4	20.142	19.495	16	33.016	32.866
5	19.619	19.002	17	31.885	31.210
6	19.541	18.993	18	31.219	30.286
7	18.807	18.126	19	21.943	21.557
8	16.686	15.898	20	21.966	21.796
9	20.646	20.455	21	21.631	21.488
10	21.402	21.188	22	21.325	21.194
11	21.383	21.141	23	21.025	20.903
12	35.062	35.036	24	20.549	20.435




Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



3.2 Air Conditioned with Night Purging Option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
49	mcc_nightp	mcc_nightp.bdf.01	99	16:06:31	03:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	227.40
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
51	mcc_nightp	mcc_nightp.bdf.01	99	16:06:52	03:Mar:03		A-Tas 8.40




Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside


Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
52	mcc_nightp	mcc_nightp.bdf.01	99	16:07:17	03:Mar:03		A-Tas 8.40




Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	0.746	2.938	13	0.063	0.063
2	0.888	1.896	14	0.063	0.063
3	0.906	1.541	15	0.063	0.063
4	0.848	1.409	16	0.063	0.063
5	0.719	1.311	17	0.063	0.063
6	0.654	1.161	18	0.063	0.063
7	0.063	0.063	19	1.627	2.156
8	0.063	0.063	20	1.150	1.120
9	0.063	0.063	21	1.001	0.976
10	0.063	0.063	22	0.901	0.875
11	0.063	0.063	23	0.815	0.789
12	0.063	0.063	24	0.661	0.638




Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
61	mcc_nightp	mcc_nightp.bdf.01	99	16:07:40	03:Mar:03		A-Tas 8.40



Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	16.194	14.128	13	17.044	16.863
2	19.651	18.622	14	16.655	16.482
3	20.695	19.988	15	16.504	16.329
4	20.672	20.025	16	16.996	16.801
5	20.155	19.478	17	17.504	17.344
6	20.090	19.499	18	17.666	17.514
7	15.300	15.145	19	26.755	26.116
8	15.587	15.369	20	24.327	24.192
9	21.039	20.850	21	23.818	23.673
10	20.255	20.061	22	23.494	23.329
11	18.944	18.739	23	23.190	22.989
12	17.890	17.644	24	22.449	22.304




Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



3.3 Air Conditioned With No Night Purging Option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
80	mcc_nightp	mcc_nopurg.bdf.01	100	16:12:29	03:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	352.65
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.36
Outside	

Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
82	mcc_nightp	mcc_nopurg.bdf.01	100	16:12:55	03:Mar:03		A-Tas 8.40





Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside

Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
83	mcc_nightp	mcc_nopurg.bdf.01	100	16:13:14	03:Mar:03		A-Tas 8.40





Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	0.063	0.063	13	0.063	0.063
2	0.063	0.063	14	0.063	0.063
3	0.063	0.063	15	0.063	0.063
4	0.063	0.063	16	0.063	0.063
5	0.063	0.063	17	0.063	0.063
6	0.063	0.063	18	0.063	0.063
7	0.063	0.063	19	0.063	0.063
8	0.063	0.063	20	0.063	0.063
9	0.063	0.063	21	0.063	0.063
10	0.063	0.063	22	0.063	0.063
11	0.063	0.063	23	0.063	0.063
12	0.063	0.063	24	0.063	0.063

Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
92	mcc_nightp	mcc_nopurg.bdf.01	100	16:13:41	03:Mar:03		A-Tas 8.40





Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)	Time (24 hr clock)	Air Flow In (kg/s)	Air Flow Out (kg/s)
1	14.905	14.796	13	14.166	14.063
2	15.135	15.011	14	14.109	14.005
3	15.335	15.191	15	14.155	14.046
4	15.421	15.260	16	15.130	14.927
5	15.561	15.355	17	15.905	15.758
6	15.679	15.460	18	16.220	16.083
7	15.634	15.426	19	16.383	16.217
8	15.491	15.341	20	16.002	15.777
9	19.075	18.888	21	16.060	15.869
10	17.042	16.839	22	16.112	15.924
11	15.945	15.772	23	16.202	16.015
12	14.890	14.767	24	16.315	16.129

Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




4 FREQUENCY RESULTANT TEMPERATURES


4.1 Fully Naturally Ventilated Option



4.2 Air Conditioned with Night Purging Option




Frequency of Resultant Temperatures for Year
Zone 10, Days 1 to 5, Hours 7 to 18




4.3 Air Conditioned With No Night Purging Option

Frequency of Resultant Temperatures for Year
Zone 8, Days 1 to 5, Hours 5 to 18





Frequency of Resultant Temperatures for Year
Zone 10, Days 1 to 5, Hours 5 to 18




5 FREQUENCY DISTRIBUTION AIR TEMPERATURES


5.1 Fully Naturally Ventilated Option



5.2 Air Conditioned with Night Purging Option




Frequency of Air Temperatures for Year
Zone 10, Days 1 to 5, Hours 7 to 18




5.3 Air Conditioned With No Night Purging Option

Frequency of Air Temperatures for Year
Zone 8, Days 1 to 5, Hours 5 to 18




Frequency of Air Temperatures for Year
Zone 10, Days 1 to 5, Hours 5 to 18




6 LOAD BREAKDOWNS


6.1 Fully Naturally Ventilated Option



6.2 Air Conditioned with Night Purging Option



6.3 Air Conditioned With No Night Purging Option



APPENDIX B – EXTERNAL WALL THERMAL MASS RESULTS


*zone 8 = mid level perimeter zone

* zone 10 = mid level office zone

1 SUMMER – DAY 15

1.1 Concrete wall option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
16	mcc_nightp	np_conc.bdf.01	129	10:17:45	05:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	93.31
8 s lvl 4,5,6	83.87
9 w lvl 4,5,6	26.54
10 office 4,5,6	672.28
11 e lvl 7,8,9	46.26
12 n lvl 7,8,9	108.98
Outside	

Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.ufl




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
18	mcc_nightp	np_conc.bdf.01	129	10:18:15	05:Mar:03		A-Tas 8.40




Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside

Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.ufl



1.2 Autoclaved aerated concrete wall option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
4	mcc_nightp	np_hebel.bdf.01	130	10:32:43	05:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	97.72
8 s lvl 4,5,6	90.42
9 w lvl 4,5,6	26.94
10 office 4,5,6	675.88
11 e lvl 7,8,9	46.77
12 n lvl 7,8,9	112.34
Outside	

Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
6	mcc_nightp	np_hebel.bdf.01	130	10:33:08	05:Mar:03		A-Tas 8.40




Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside

Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



1.3 Plasterboard wall option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
2	mcc_nightp	np_plast.bdf.01	127	10:09:47	05:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	104.75
8 s lvl 4,5,6	101.58
9 w lvl 4,5,6	27.75
10 office 4,5,6	681.40
11 e lvl 7,8,9	47.60
12 n lvl 7,8,9	117.61
Outside	

Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
4	mcc_nightp	np_plast.bdf.01	127	10:10:33	05:Mar:03		A-Tas 8.40



Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside


Day 15: Monday, Jan 15 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



2 MID-SEASON – DAY 80

2.1 Concrete wall option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
20	mcc_nightp	np_conc.bdf.01	129	10:19:42	05:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	29.22
8 s lvl 4,5,6	10.83
9 w lvl 4,5,6	6.16
10 office 4,5,6	528.03
11 e lvl 7,8,9	17.08
12 n lvl 7,8,9	80.45
Outside	

Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
22	mcc_nightp	np_conc.bdf.01	129	10:20:09	05:Mar:03		A-Tas 8.40




Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside

Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



2.2 Autoclaved aerated concrete wall option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
8	mcc_nightp	np_hebel.bdf.01	130	10:33:57	05:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	32.90
8 s lvl 4,5,6	16.39
9 w lvl 4,5,6	6.34
10 office 4,5,6	529.83
11 e lvl 7,8,9	17.45
12 n lvl 7,8,9	84.86
Outside	


Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
10	mcc_nightp	np_hebel.bdf.01	130	10:34:23	05:Mar:03		A-Tas 8.40



Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside




Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



2.3 Plasterboard wall option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
6	mcc_nightp	np_plast.bdf.01	127	10:11:21	05:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	38.04
8 s lvl 4,5,6	25.25
9 w lvl 4,5,6	6.71
10 office 4,5,6	533.12
11 e lvl 7,8,9	17.97
12 n lvl 7,8,9	92.13
Outside	

Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
8	mcc_nightp	np_plast.bdf.01	127	10:11:47	05:Mar:03		A-Tas 8.40



Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside


Day 80: Wednesday, Mar 21 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



3 WINTER – DAY 180

3.1 Concrete wall option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
24	mcc_nightp	np_conc.bdf.01	129	10:20:58	05:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	224.78
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	


Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
26	mcc_nightp	np_conc.bdf.01	129	10:21:22	05:Mar:03		A-Tas 8.40



Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside




Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



3.2 Autoclaved aerated concrete wall option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
12	mcc_nightp	np_hebel.bdf.01	130	10:34:55	05:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	0.00

Zone	Cooling (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	240.06
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	0.00


Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
14	mcc_nightp	np_hebel.bdf.01	130	10:35:21	05:Mar:03		A-Tas 8.40



Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside




Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1



3.3 Plasterboard wall option


Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
10	mcc_nightp	np_plast.bdf.01	127	10:12:54	05:Mar:03		A-Tas 8.40




Zone	Heating (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	0.00
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.00
Outside	

Zone	Cooling (kWh)
7 n lvl 4,5,6	0.00
8 s lvl 4,5,6	0.00
9 w lvl 4,5,6	0.00
10 office 4,5,6	259.44
11 e lvl 7,8,9	0.00
12 n lvl 7,8,9	0.06
Outside	

Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




Page	Building Name	Building Data File	Version	Time	Date	Consultant	Program
12	mcc_nightp	np_plast.bdf.01	127	10:13:18	05:Mar:03		A-Tas 8.40





Zone
7 n lvl 4,5,6
8 s lvl 4,5,6
9 w lvl 4,5,6
10 office 4,5,6
11 e lvl 7,8,9
12 n lvl 7,8,9
Outside

Day 180: Friday, Jun 29 (WEEKDAY)
Weather: AUS_Melbourne_TRY.wf1




4 FREQUENCY DISTRIBUTION OF RESULTANT TEMPERATURES


4.1 Concrete wall option



4.2 Autoclaved aerated concrete wall option




Frequency of Resultant Temperatures for Year
Zone 10, Days 1 to 5, Hours 7 to 18




4.3 Plasterboard wall option

Frequency of Resultant Temperatures for Year
Zone 8, Days 1 to 5, Hours 7 to 18





Frequency of Resultant Temperatures for Year
Zone 10, Days 1 to 5, Hours 7 to 18




5 FREQUENCY OF AIR TEMPERATURES


5.1 Concrete wall option



5.2 Autoclaved aerated concrete wall option




Frequency of Air Temperatures for Year
Zone 10, Days 1 to 5, Hours 7 to 18




5.3 Plasterboard wall option

Frequency of Air Temperatures for Year
Zone 8, Days 1 to 5, Hours 7 to 18




Frequency of Air Temperatures for Year
Zone 10, Days 1 to 5, Hours 7 to 18




6 LOAD BREAKDOWNS

6.1 Concrete wall option



6.2 Autoclaved aerated concrete wall option



6.3 Plasterboard wall option

